

TEKIPPE ENGINEERING, P.C.

Engineers – Land Surveyors

www.tekippe.com

1919 210TH STREET
PO BOX 357
MANCHESTER, IA 52057
PHONE 563-927-2060
FAX 563-927-3603

128 S. VINE STREET
WEST UNION, IA 52175
PHONE 563-422-5131
FAX 563-422-5884

375 COLLINS RD NE
SUITE 105
CEDAR RAPIDS, IA 52402
PHONE 319-294-6909
FAX 319-294-5133

**ADDENDUM NUMBER #1
TO
2010 WATER MAIN IMPROVEMENTS
CENTER POINT, IOWA
JUNE 2010
PROJECT No. 092000.MS & 092001.MS**

A. ITEM CODE 7060-108-A-0 Bituminous Double Seal Coat Clarification:


The bid item for Bituminous Seal Coat shall be a Double Seal Coat as listed in the Supplemental Specifications on Sheet C.03 and in the Form of Proposal.

B. SECTION 5030, Part 3.06 – BACTERIA SAMPLING

Per AWWA C651 – Standard for Disinfecting, when any existing mains are wholly or partially dewatered to complete any connection or abandonment bacteriological testing must be completed. The existing main may be returned to service prior to the completion of the bacteriological testing in order to minimize the time customers are without water. Daily sampling shall be continued until two consecutive negative samples are recorded. The contractor shall be responsible for this sampling. For projects 092000.MS and 092001.MS testing will be paid for as part of the Connection to Existing Water Main (5010-108-E-0) and Water Main Abandonment (5010-108-G-0) bid items. For the Optional work on project 092001.MS the connection to existing mains, abandonment, and testing will be paid for under the mobilization bid item.

C. ADDENDUM ACKNOWLEDGEMENT

Bidders are reminded to acknowledge this addendum in Part B on the first page of the Form of Proposal.

	<p>I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.</p> <hr/> <p>Ryan M. Wicks, P.E. Date License Number 16341 My license renewal date is December 31, 2011. Pages covered by this seal: Page 1 of 1</p>
-------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------